

NOTICE 661 OF 2007**DEPARTMENT OF PUBLIC WORKS
AGREMENT SOUTH AFRICA**
(Approval of innovative construction products and systems)

Notice is hereby given that Agreement South Africa has, with effect from 29 March 2007, issued an Agreement certificate, details of which appear in the schedule hereto.

SCHEDULE
Agreement Certificate No 2007/332

Name of product: Gundle UT Woven Tile Underlay

Certificate holder: Gundle API (Pty) Ltd

Description: The Gundle UT Woven Tile Underlay is manufactured from a laminate of spunbonded material and virgin polyethylene. The spunbond layers are UV-stabilised. The membrane has a weight of 142 g/m² and the thickness vary between 0,305 mm to 0,335 mm. It is supplied in rolls of 30 m, 40 m long and 1, 25 m wide.

Gundle UT Woven Tile Underlay is suitable for installation in all tiled-roof buildings with timber roof construction having a pitch of less than 60 degree. It was not evaluated for metal roof construction and side-wall cladding. It can be used in all regions of South Africa when used in the conventional manner to:

- reduce air movement between tiles, since the membrane can contribute to maintaining a balanced air pressure on both sides of the roof tiles
- reduce ingress to the roof space of wind-driven rain and dust.

The Agreement certificate contains detailed information on the product and can be accessed at <http://w.agreement.co.za>

Copies are obtainable from: The Manager
Agreement South Africa
P O Box 395
0001 PRETORIA