

NOTICE 212 OF 2010**DEPARTMENT OF PUBLIC WORKS
AGRÉMENT SOUTH AFRICA**

(Approval of innovative construction products and systems)

Notice is hereby given that Agrément South Africa has, with effect from 13 May 2009, issued an Agrément certificate, details of which appear in the schedule hereto.

SCHEDULE

Agrément Certificate No 2009/359

Name of product: JoJo Septic Tanks

Certificate holder: JoJo Tanks (Pty) Ltd

Description: The JoJo Septic Tank is a prefabricated and rotary-moulded polyethylene digester tank. It is available in liquid capacities of 1250, 1500, 1750, 2000 and 2500 litres. It is fitted with a 110 mm inlet and 50 mm outlet pipes and a 390 mm diameter lid which is filled with concrete after installation of the septic tank.

The digester facilitates the separation of solids and bio-degradation (both in the form of floating scum and settled sludge), from the liquid fraction of the waste to a level that the effluent from the digester can be discharged into a sub-soil percolation system (soak-away or French drain) in accordance with **SANS 10400: Part P (Drainage)** and specific rule PP28 (in-situ percolation test for soils) or transported by a sewer to a treatment facility.

The Agrément certificate contains detailed information on the product and can be accessed at <http://www.agrement.co.za>

Copies are obtainable from: The Manager
Agrément South Africa
P O Box 395
0001 PRETORIA