

---

## GOVERNMENT NOTICE

---

### DEPARTMENT OF WATER AFFAIRS

R. 826

25 October 2013

### WATER SERVICES ACT, 1997

### REGULATIONS RELATING TO COMPULSORY NATIONAL STANDARDS FOR PROCESS CONTROLLERS AND WATER SERVICES WORKS

### CORRECTION NOTICE

Government Notice No. 10040, published in Government Gazette No. 36958 of 23 October 2013 is hereby amended as follows:

On page 19, add the following schedule after paragraph 1.6:

## SCHEDULE 4

**MINIMUM CLASS OF PROCESS CONTROLLER REQUIRED PER SHIFT, AND SUPERVISION, OPERATIONS AND MAINTENANCE  
SUPPORT SERVICES REQUIREMENTS AT A WATER SERVICES WORKS**

WORKS CLASS	CLASS OF PROCESS CONTROLLER PER SHIFT	CLASS OF PROCESS CONTROLLER FOR SUPERVISION*	OPERATIONS AND MAINTENANCE SUPPORT SERVICES REQUIREMENTS*
E	Class I	Class V*	THESE PERSONNEL MUST BE AVAILABLE AT ALL TIMES BUT MAY BE IN-HOUSE OR OUTSOURCED - electrician - fitter - instrumentation technician
D	Class II	Class V*	
C	Class III	Class V*	
B	Class IV	Class V	
A	Class IV	Class V	

NB. Fluoridation – for any class works, minimum process controller classification should be class IV

## NOTES FOR SCHEDULES IV

\*does not have to be at the water services works at all times but must be available at all times. If the Water Services Institution or owner of a water services works has no person of this class employed on that water services works, a contractor / consultant with the required qualifications as prescribed in Schedule III in respect of that particular class of persons shall be appointed to visit the water services works weekly.