

NOTICE 470 OF 2014**DEPARTMENT OF PUBLIC WORKS****AGRÉMENT SOUTH AFRICA**

(Approval of innovative construction products and systems)

Notice is hereby given that Agrément South Africa has, with effect from 12 December 2012, issued an Agrément certificate, details of which appear in the schedule hereto.

SCHEDULE

Agrément Certificate 2009/359(Amended December 2012)

Name of product: JoJo Septic Tanks

Certificate holder: JoJo Tanks (Pty) Ltd

Description: The JoJo Septic Tank is a rotary-moulded polyethylene digester tank. It is available in liquid capacities of 1250, 1500, 1750, 2000, 2500 litres and 600 litre Conservancy tank.

The septic tank is fitted with a 110 mm inlet and 50 mm outlet pipes and a 390 mm diameter lid which is filled with concrete after installation of the septic tank. The 6000 litre conservancy tank is fitted with the same inlet and outlet pipe as the septic tank and 415 mm diameter lid.

The digester facilitates the separation of solids and bio-degradation (both in the form of floating scum and settled sludge), from the liquid fraction of the waste to a level that the effluent from the digester can be discharged into a sub-soil percolation system (soak-away or French drain) in accordance with **SANS 10400: Part P (Drainage)** and specific rule PP28 (*in-situ* percolation test for soils) or transported by a sewer to a treatment facility.

The Agrément certificate contains detailed information on the product and can be accessed at <http://www.agrement.co.za>

Copies are obtainable from: Chief Executive Officer (CEO)
Agrément South Africa
P O Box 395
0001
PRETORIA