

DEPARTMENT OF PUBLIC WORKS

NO. 203

22 FEBRUARY 2019

AGRÉMENT SOUTH AFRICA
(Approval of innovative construction products and systems)

Notice is hereby given that Agrément South Africa has, with effect from 18 October 2018, issued an Agrément certificate, details of which appear in the schedule hereto.

SCHEDULE
Agrément Certificate 2018/579

Subject: Sisalation Fireshield DS Roofing Radiant Insulation Barrier

Certificate holder: Afripack Consumer Flexibles (Pty) Ltd

Description: Sisalation Fireshield DS Roofing Radiant Insulation Barrier is a double sided aluminium foil roofing radiant insulation barrier membrane manufactured from two outer layers of aluminium foil laminated with flame retarded adhesives on both sides of an intermediate fibreglass mesh reinforcement layer.

The membrane has an overall weight of 154 g/m² with a thickness of between 0.11 mm and 0.13 mm. It is supplied in rolls of 40 m long and 1.25 m wide.

Sisalation Fireshield DS Roofing Radiant Insulation Barrier is suitable for installation in industrial buildings when used in conjunction with steel roof construction with galvanised sheet steel cladding and side claddings. It can be used in all regions of South Africa for industrial types of occupancy classification (**SANS 10400**: Table 1 of regulation A (20) (1)). When used in the conventional manner it can:

- reduce air leakage and
- reduce ingress to the roof space of wind-driven rain and dust.

The Agrément certificate contains detailed information on the product and can be accessed at <http://www.agrement.co.za>

Copies are obtainable from: Chief Executive Officer (CEO)
Agrément South Africa, P O Box 72381, LYNNWOOD RIDGE, 0040